

TECHNICAL SPECIFICATIONS AND DETAIL DRAWINGS FOR WATER LINE AND SEWER LINE CONSTRUCTION (JANUARY 2019)

Section A, page A-1 is revised as follows:

CAST IRON SOIL PIPE AND FITTINGS: All cast iron soil pipe and fittings will conform to ASTM A74 and be classified as SV (service weight). Single or double hub is acceptable. No-hub pipe shall not be used. All pipe and fittings shall be uniformly coated with bituminous coating. Joints will be rubber gasket. Rubber gaskets shall conform to ASTM C564. 4" x 4" combination wye and eighth bends shall be ~~short~~long pattern - Fig. No. SV-~~32-33~~ by Charlotte Pipe and Foundry (or approved equal). 4" cleanouts shall consist of a 4" service weight cast iron ferrule (with 3" iron pipe size tap) and a 3" brass plug. The plug shall have a low raised square head (Southern Code). Cleanouts shall be Part Number 184 by Jumbo Manufacturing Company (or approved equal).